


District Name: Bhajpur (Ar)

Sample Collected By:- School Staff

Government of Bihar  
Public Health Engineering Department  
Monthly Water Quality Monitoring Report  
Division Name: P.H. Division, Ar

District Lab, Ar  
Month:- February '22

Sl. No.	Block	Panchyat	Village	Habitation	Location of Source	Date of Sampling	Date of Testing	Parameters																				Remarks
								pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Albu	Fe	NO <sub>3</sub>	SO <sub>4</sub>	F	As	Total Cal						
1	2	3		4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23					
1	Usonnagar	Etarna	Asaith	Zero Mile	KendryaVidyalaya Ar (R.O.W)	19.02.22	22.02.22	7.26	1.2	360	288	150	32	18.8	24	168	0.3	NT	NT	0.08	BDL	NT	Safe					
2	Usonnagar	Etarna	Asaith	Zero Mile	KendryaVidyalaya Ar (R.O.W)	19.02.22	22.02.22	6.91	0.8	80	48	20	4	2.4	5	24	0.1	NT	NT	0.04	BDL	NT	Safe					
3	Usonnagar	Etarna	Asaith	Zero Mile	KendryaVidyalaya Ar (R.O.W)	19.02.22	22.02.22	6.95	0.7	64	50	24	4	3.36	5	24	0.1	NT	NT	0.04	BDL	NT	Safe					
Permissible Limit in absence of alternative source								8.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	-					
*NT= Not Tested, BDL=Below Detection Limit								N/R	5	-	2000	600	200	100	1000	600	N/R	N/R	400	1.5	N/R	-	-					

  
 P. H. Engineer  
 22/02/22  
 22.02.22  
 P. H. Div